

# Drinking Water Quality Notification

Child Care or School Name: Barrows Elementary

Date: 4/14/2025

We are committed to protecting the health of children, teachers, and staff so we participated in the Drinking Water Lead Testing Program, which is a federal grant program administered by the Michigan Department of Environment, Great Lakes, and Energy (EGLE). By volunteering for this program, the drinking water and food preparation taps were tested for lead and we have taken steps to reduce the risk of lead exposure in the drinking water.

You can see a copy of the water testing results in the administration office. For more information about water quality in our facility, please contact Brian Leonard, Director of Facilities & Operations at (269) 279-1119 (phone).

## What actions have been/are being taken to reduce the risk of lead exposure in the drinking water?

- ☒ Taps with lead results greater than 0.005 milligrams per liter (mg/L) have been taken out of service unless it is a tap needed for handwashing (a sign is posted that it is not to be used for drinking)
- ☒ Replacing older fixtures and drinking fountains with certified-lead free fixtures
- ☒ Installing filtered bottle fill drinking fountain units or lead reduction filters on other taps
- ☒ Moving the water (flushing) on a regular basis to decrease the time water stays in the pipes
- ☒ Educating everyone to let the water run for at least 30 seconds before drinking or filling bottles
- ☒ Using signs or other means to indicate what taps can be used for drinking, bottle filling or cooking or using signs to indicate where everyone should not drink, bottle fill, or cook from (e.g., handwashing only)
- ☒ Educating the children on proper drinking locations
- ☒ Cleaning aerators and screens at drinking water fixtures on a routine basis
- ☒ Using only cold water for drinking and cooking
- ☒ Follow up sampling as needed
- ☐ Other: \_\_\_\_\_

## What Are the Health Effects of Lead?

Lead is a toxic metal that is harmful to human health if inhaled or swallowed. Lead exposure may from lead-based paint, dust, soil, air, food, water, and some consumer products. The degree of harm from lead exposure depends on several factors including the frequency, duration, and level of the exposure(s) along with age, nutrition, health, and previous exposure history. There is no safe blood lead level for children. The only way to determine a child's lead level is to have the child's blood tested. Contact your doctor or a health provider to learn more about blood testing.

## Want More Information?

For information about water quality and sampling for lead at home, contact your local water supplier or go to the following website: [Michigan.gov/MILeasSafe](https://Michigan.gov/MILeasSafe). EGLE recommends that taps for drinking water or food preparation in a child care facility or school that have a test result greater than 0.005 milligrams per liter (mg/L) be taken out of service immediately until the risk of lead exposure can be reduced at that tap.

## This Public Notification is being distributed through the following means:

- ☐ Posting in Common Areas of the Building
- ☒ E-mail or Letter to Parents, Teachers, and Staff
- ☒ Posting on Website
- ☐ Handout to every parent or guardian
- ☒ Newsletter

## Signed and Certified

Brian Leonard, Director of Facilities & Operations  
Name and Title

4/14/2025  
Date

(Administrator - Please email a copy of this signed notice to: [EGLE-DWEHD-Schoolwater@Michigan.gov](mailto:EGLE-DWEHD-Schoolwater@Michigan.gov) or mail a copy to: EGLE-DWEHD-CWSS-LCU, P.O. Box 30817, Lansing, Michigan 48909-8311, or fax to: 517-241-1328. Thank you!)

## Official Laboratory Report

Report To: HOLLY GOHLKE  
EGLE-DWEHD-CWSS-LCU  
PO BOX 30817  
LANSING MI 48909-8311

**Sample ID: LL62400**  
**Work Order: 50400091\_01**

System Name/Owner:	01640-BARROWS SCHOOL	WSSN/Pool ID:	
Collection Address:	416 WASHINGTON ST, THREE RIVERS	Source:	Other
Collected By:	ANDY WERT	Site Code:	WIIN
Township/Well#/Section:	//	Collector:	Other
County:	St Joseph	Date Collected:	03/28/2025 10:47
Sample Point:	BAR-KIT-KF	Date Received:	04/01/2025 13:58
Water System:	Other	Purpose:	Other

TESTING INFORMATION					REGULATORY INFORMATION		
Analyte Name	Result	Units	RL	Date Tested	MCL/AL	Method	CAS #
Lead	0.003	mg/L	0.001	04/03/2025	0.012	EPA 200.8	7439-92-1

The analyses performed by the EGLE Drinking Water Laboratory were conducted using methods approved by the U.S. Environmental Protection Agency in accordance with the Safe Drinking Water Act, 40 CFR parts 141-143, and other regulatory agencies as appropriate.

**Your local health department has detailed information about the quality of drinking water in your area. If you have concerns about the health risks related to the test results of your sample, please contact the Environmental Health Section through the address and telephone number listed below.**

**Branch-Hillsdale-St. Joseph Health Dept**  
**1110 Hill St.**  
**Three Rivers, MI 49093**  
**269 273-2161**

RL: Reporting Limit  
MCL: Maximum Contaminant Level  
AL: Action Level  
Not Detected: Not detected at or above the reporting limit (RL)

mg/L: milligrams / Liter (ppm)  
ng/L: nanograms / Liter (ppt)  
MPN: Most Probable Number

CFU: Colony Forming Unit  
CAS: Chemical Abstract Service  
Laboratory Contact: Marlene Kane

## Official Laboratory Report

Report To: HOLLY GOHLKE  
EGLE-DWEHD-CWSS-LCU  
PO BOX 30817  
LANSING MI 48909-8311

**Sample ID: LL62401**  
**Work Order: 50400091\_02**

System Name/Owner:	01640-BARROWS SCHOOL	WSSN/Pool ID:	
Collection Address:	416 WASHINGTON ST, THREE RIVERS	Source:	Other
Collected By:	ANDY WERT	Site Code:	WIIN
Township/Well#/Section:	//	Collector:	Other
County:	St Joseph	Date Collected:	03/28/2025 10:47
Sample Point:	BAR-KIT-KF-F	Date Received:	04/01/2025 13:58
Water System:	Other	Purpose:	Other

TESTING INFORMATION					REGULATORY INFORMATION		
Analyte Name	Result	Units	RL	Date Tested	MCL/AL	Method	CAS #
Lead	0.001	mg/L	0.001	04/03/2025	0.012	EPA 200.8	7439-92-1

The analyses performed by the EGLE Drinking Water Laboratory were conducted using methods approved by the U.S. Environmental Protection Agency in accordance with the Safe Drinking Water Act, 40 CFR parts 141-143, and other regulatory agencies as appropriate.

**Your local health department has detailed information about the quality of drinking water in your area. If you have concerns about the health risks related to the test results of your sample, please contact the Environmental Health Section through the address and telephone number listed below.**

**Branch-Hillsdale-St. Joseph Health Dept**  
**1110 Hill St.**  
**Three Rivers, MI 49093**  
**269 273-2161**

RL: Reporting Limit  
MCL: Maximum Contaminant Level  
AL: Action Level  
Not Detected: Not detected at or above the reporting limit (RL)

mg/L: milligrams / Liter (ppm)  
ng/L: nanograms / Liter (ppt)  
MPN: Most Probable Number

CFU: Colony Forming Unit  
CAS: Chemical Abstract Service  
Laboratory Contact: Marlene Kane

## Official Laboratory Report

Report To: HOLLY GOHLKE  
EGLE-DWEHD-CWSS-LCU  
PO BOX 30817  
LANSING MI 48909-8311

**Sample ID: LL62402**  
**Work Order: 50400091\_03**

System Name/Owner:	01640-BARROWS SCHOOL	WSSN/Pool ID:	
Collection Address:	416 WASHINGTON ST, THREE RIVERS	Source:	Other
Collected By:	ANDY WERT	Site Code:	WIIN
Township/Well#/Section:	//	Collector:	Other
County:	St Joseph	Date Collected:	03/28/2025 10:48
Sample Point:	BAR-KIT-2-KF	Date Received:	04/01/2025 13:58
Water System:	Other	Purpose:	Other

TESTING INFORMATION					REGULATORY INFORMATION		
Analyte Name	Result	Units	RL	Date Tested	MCL/AL	Method	CAS #
Lead	0.002	mg/L	0.001	04/03/2025	0.012	EPA 200.8	7439-92-1

The analyses performed by the EGLE Drinking Water Laboratory were conducted using methods approved by the U.S. Environmental Protection Agency in accordance with the Safe Drinking Water Act, 40 CFR parts 141-143, and other regulatory agencies as appropriate.

**Your local health department has detailed information about the quality of drinking water in your area. If you have concerns about the health risks related to the test results of your sample, please contact the Environmental Health Section through the address and telephone number listed below.**

**Branch-Hillsdale-St. Joseph Health Dept**  
**1110 Hill St.**  
**Three Rivers, MI 49093**  
**269 273-2161**

RL: Reporting Limit  
MCL: Maximum Contaminant Level  
AL: Action Level  
Not Detected: Not detected at or above the reporting limit (RL)

mg/L: milligrams / Liter (ppm)  
ng/L: nanograms / Liter (ppt)  
MPN: Most Probable Number

CFU: Colony Forming Unit  
CAS: Chemical Abstract Service  
Laboratory Contact: Marlene Kane

### Official Laboratory Report

Report To: HOLLY GOHLKE  
EGLE-DWEHD-CWSS-LCU  
PO BOX 30817  
LANSING MI 48909-8311

**Sample ID: LL62403**  
**Work Order: 50400091\_04**

System Name/Owner:	01640-BARROWS SCHOOL	WSSN/Pool ID:	
Collection Address:	416 WASHINGTON ST, THREE RIVERS	Source:	Other
Collected By:	ANDY WERT	Site Code:	WIIN
Township/Well#/Section:	//	Collector:	Other
County:	St Joseph	Date Collected:	03/28/2025 10:48
Sample Point:	BAR-KIT-2-KF-F	Date Received:	04/01/2025 13:58
Water System:	Other	Purpose:	Other

TESTING INFORMATION					REGULATORY INFORMATION		
Analyte Name	Result	Units	RL	Date Tested	MCL/AL	Method	CAS #
Lead	0.001	mg/L	0.001	04/03/2025	0.012	EPA 200.8	7439-92-1

The analyses performed by the EGLE Drinking Water Laboratory were conducted using methods approved by the U.S. Environmental Protection Agency in accordance with the Safe Drinking Water Act, 40 CFR parts 141-143, and other regulatory agencies as appropriate.

**Your local health department has detailed information about the quality of drinking water in your area. If you have concerns about the health risks related to the test results of your sample, please contact the Environmental Health Section through the address and telephone number listed below.**

**Branch-Hillsdale-St. Joseph Health Dept**  
**1110 Hill St.**  
**Three Rivers, MI 49093**  
**269 273-2161**

RL: Reporting Limit  
MCL: Maximum Contaminant Level  
AL: Action Level  
Not Detected: Not detected at or above the reporting limit (RL)

mg/L: milligrams / Liter (ppm)  
ng/L: nanograms / Liter (ppt)  
MPN: Most Probable Number

CFU: Colony Forming Unit  
CAS: Chemical Abstract Service  
Laboratory Contact: Marlene Kane

Official Laboratory Report

Report To: HOLLY GOHLKE  
EGLE-DWEHD-CWSS-LCU  
PO BOX 30817  
LANSING MI 48909-8311

**Sample ID: LL62404**  
**Work Order: 50400091\_05**

System Name/Owner:	01640-BARROWS SCHOOL	WSSN/Pool ID:	
Collection Address:	416 WASHINGTON ST, THREE RIVERS	Source:	Other
Collected By:	ANDY WERT	Site Code:	WIIN
Township/Well#/Section:	//	Collector:	Other
County:	St Joseph	Date Collected:	03/28/2025 10:51
Sample Point:	BAR-1HALL-DF	Date Received:	04/01/2025 13:58
Water System:	Other	Purpose:	Other

TESTING INFORMATION					REGULATORY INFORMATION		
Analyte Name	Result	Units	RL	Date Tested	MCL/AL	Method	CAS #
Lead	0.306	mg/L	0.001	04/04/2025	0.012	EPA 200.8	7439-92-1

The analyses performed by the EGLE Drinking Water Laboratory were conducted using methods approved by the U.S. Environmental Protection Agency in accordance with the Safe Drinking Water Act, 40 CFR parts 141-143, and other regulatory agencies as appropriate.

**Your local health department has detailed information about the quality of drinking water in your area. If you have concerns about the health risks related to the test results of your sample, please contact the Environmental Health Section through the address and telephone number listed below.**

**Branch-Hillsdale-St. Joseph Health Dept**  
**1110 Hill St.**  
**Three Rivers, MI 49093**  
**269 273-2161**

RL: Reporting Limit  
MCL: Maximum Contaminant Level  
AL: Action Level  
Not Detected: Not detected at or above the reporting limit (RL)

mg/L: milligrams / Liter (ppm)  
ng/L: nanograms / Liter (ppt)  
MPN: Most Probable Number

CFU: Colony Forming Unit  
CAS: Chemical Abstract Service  
Laboratory Contact: Marlene Kane

## Official Laboratory Report

Report To: HOLLY GOHLKE  
EGLE-DWEHD-CWSS-LCU  
PO BOX 30817  
LANSING MI 48909-8311

**Sample ID: LL62405**  
**Work Order: 50400091\_06**

System Name/Owner:	01640-BARROWS SCHOOL	WSSN/Pool ID:	
Collection Address:	416 WASHINGTON ST, THREE RIVERS	Source:	Other
Collected By:	ANDY WERT	Site Code:	WIIN
Township/Well#/Section:	//	Collector:	Other
County:	St Joseph	Date Collected:	03/28/2025 10:51
Sample Point:	BAR-1HALL-DF-F	Date Received:	04/01/2025 13:58
Water System:	Other	Purpose:	Other

TESTING INFORMATION					REGULATORY INFORMATION		
Analyte Name	Result	Units	RL	Date Tested	MCL/AL	Method	CAS #
Lead	0.092	mg/L	0.001	04/04/2025	0.012	EPA 200.8	7439-92-1

The analyses performed by the EGLE Drinking Water Laboratory were conducted using methods approved by the U.S. Environmental Protection Agency in accordance with the Safe Drinking Water Act, 40 CFR parts 141-143, and other regulatory agencies as appropriate.

**Your local health department has detailed information about the quality of drinking water in your area. If you have concerns about the health risks related to the test results of your sample, please contact the Environmental Health Section through the address and telephone number listed below.**

**Branch-Hillsdale-St. Joseph Health Dept**  
**1110 Hill St.**  
**Three Rivers, MI 49093**  
**269 273-2161**

RL: Reporting Limit  
MCL: Maximum Contaminant Level  
AL: Action Level  
Not Detected: Not detected at or above the reporting limit (RL)

mg/L: milligrams / Liter (ppm)  
ng/L: nanograms / Liter (ppt)  
MPN: Most Probable Number

CFU: Colony Forming Unit  
CAS: Chemical Abstract Service  
Laboratory Contact: Marlene Kane

Official Laboratory Report

Report To: HOLLY GOHLKE  
EGLE-DWEHD-CWSS-LCU  
PO BOX 30817  
LANSING MI 48909-8311

**Sample ID: LL62406**  
**Work Order: 50400091\_07**

System Name/Owner:	01640-BARROWS SCHOOL	WSSN/Pool ID:	
Collection Address:	416 WASHINGTON ST, THREE RIVERS	Source:	Other
Collected By:	ANDY WERT	Site Code:	WIIN
Township/Well#/Section:	//	Collector:	Other
County:	St Joseph	Date Collected:	03/28/2025 10:53
Sample Point:	BAR-1HALL-2-DF	Date Received:	04/01/2025 13:58
Water System:	Other	Purpose:	Other

TESTING INFORMATION					REGULATORY INFORMATION		
Analyte Name	Result	Units	RL	Date Tested	MCL/AL	Method	CAS #
Lead	0.230	mg/L	0.001	04/04/2025	0.012	EPA 200.8	7439-92-1

The analyses performed by the EGLE Drinking Water Laboratory were conducted using methods approved by the U.S. Environmental Protection Agency in accordance with the Safe Drinking Water Act, 40 CFR parts 141-143, and other regulatory agencies as appropriate.

**Your local health department has detailed information about the quality of drinking water in your area. If you have concerns about the health risks related to the test results of your sample, please contact the Environmental Health Section through the address and telephone number listed below.**

**Branch-Hillsdale-St. Joseph Health Dept**  
**1110 Hill St.**  
**Three Rivers, MI 49093**  
**269 273-2161**

RL: Reporting Limit  
MCL: Maximum Contaminant Level  
AL: Action Level  
Not Detected: Not detected at or above the reporting limit (RL)

mg/L: milligrams / Liter (ppm)  
ng/L: nanograms / Liter (ppt)  
MPN: Most Probable Number

CFU: Colony Forming Unit  
CAS: Chemical Abstract Service  
Laboratory Contact: Marlene Kane



### Official Laboratory Report

Report To: HOLLY GOHLKE  
EGLE-DWEHD-CWSS-LCU  
PO BOX 30817  
LANSING MI 48909-8311

**Sample ID: LL62407**  
**Work Order: 50400091\_08**

System Name/Owner:	01640-BARROWS SCHOOL	WSSN/Pool ID:	
Collection Address:	416 WASHINGTON ST, THREE RIVERS	Source:	Other
Collected By:	ANDY WERT	Site Code:	WIIN
Township/Well#/Section:	//	Collector:	Other
County:	St Joseph	Date Collected:	03/28/2025 10:53
Sample Point:	BAR-1HALL-2-DF-F	Date Received:	04/01/2025 13:58
Water System:	Other	Purpose:	Other

TESTING INFORMATION					REGULATORY INFORMATION		
Analyte Name	Result	Units	RL	Date Tested	MCL/AL	Method	CAS #
Lead	0.049	mg/L	0.001	04/03/2025	0.012	EPA 200.8	7439-92-1

The analyses performed by the EGLE Drinking Water Laboratory were conducted using methods approved by the U.S. Environmental Protection Agency in accordance with the Safe Drinking Water Act, 40 CFR parts 141-143, and other regulatory agencies as appropriate.

**Your local health department has detailed information about the quality of drinking water in your area. If you have concerns about the health risks related to the test results of your sample, please contact the Environmental Health Section through the address and telephone number listed below.**

**Branch-Hillsdale-St. Joseph Health Dept**  
**1110 Hill St.**  
**Three Rivers, MI 49093**  
**269 273-2161**

RL: Reporting Limit  
MCL: Maximum Contaminant Level  
AL: Action Level  
Not Detected: Not detected at or above the reporting limit (RL)

mg/L: milligrams / Liter (ppm)  
ng/L: nanograms / Liter (ppt)  
MPN: Most Probable Number

CFU: Colony Forming Unit  
CAS: Chemical Abstract Service  
Laboratory Contact: Marlene Kane

Official Laboratory Report

Report To: HOLLY GOHLKE  
EGLE-DWEHD-CWSS-LCU  
PO BOX 30817  
LANSING MI 48909-8311

**Sample ID: LL62408**  
**Work Order: 50400091\_09**

System Name/Owner:	01640-BARROWS SCHOOL	WSSN/Pool ID:	
Collection Address:	416 WASHINGTON ST, THREE RIVERS	Source:	Other
Collected By:	ANDY WERT	Site Code:	WIIN
Township/Well#/Section:	//	Collector:	Other
County:	St Joseph	Date Collected:	03/28/2025 10:56
Sample Point:	BAR-106-TL	Date Received:	04/01/2025 13:58
Water System:	Other	Purpose:	Other

TESTING INFORMATION					REGULATORY INFORMATION		
Analyte Name	Result	Units	RL	Date Tested	MCL/AL	Method	CAS #
Lead	0.001	mg/L	0.001	04/03/2025	0.012	EPA 200.8	7439-92-1

The analyses performed by the EGLE Drinking Water Laboratory were conducted using methods approved by the U.S. Environmental Protection Agency in accordance with the Safe Drinking Water Act, 40 CFR parts 141-143, and other regulatory agencies as appropriate.

**Your local health department has detailed information about the quality of drinking water in your area. If you have concerns about the health risks related to the test results of your sample, please contact the Environmental Health Section through the address and telephone number listed below.**

**Branch-Hillsdale-St. Joseph Health Dept**  
**1110 Hill St.**  
**Three Rivers, MI 49093**  
**269 273-2161**

RL: Reporting Limit  
MCL: Maximum Contaminant Level  
AL: Action Level  
Not Detected: Not detected at or above the reporting limit (RL)

mg/L: milligrams / Liter (ppm)  
ng/L: nanograms / Liter (ppt)  
MPN: Most Probable Number

CFU: Colony Forming Unit  
CAS: Chemical Abstract Service  
Laboratory Contact: Marlene Kane

## Official Laboratory Report

Report To: HOLLY GOHLKE  
EGLE-DWEHD-CWSS-LCU  
PO BOX 30817  
LANSING MI 48909-8311

**Sample ID: LL62409**  
**Work Order: 50400091\_10**

System Name/Owner:	01640-BARROWS SCHOOL	WSSN/Pool ID:	
Collection Address:	416 WASHINGTON ST, THREE RIVERS	Source:	Other
Collected By:	ANDY WERT	Site Code:	WIIN
Township/Well#/Section:	//	Collector:	Other
County:	St Joseph	Date Collected:	03/28/2025 10:56
Sample Point:	BAR-106-TL-F	Date Received:	04/01/2025 13:58
Water System:	Other	Purpose:	Other

TESTING INFORMATION					REGULATORY INFORMATION		
Analyte Name	Result	Units	RL	Date Tested	MCL/AL	Method	CAS #
Lead	Not detected	mg/L	0.001	04/03/2025	0.012	EPA 200.8	7439-92-1

The analyses performed by the EGLE Drinking Water Laboratory were conducted using methods approved by the U.S. Environmental Protection Agency in accordance with the Safe Drinking Water Act, 40 CFR parts 141-143, and other regulatory agencies as appropriate.

**Your local health department has detailed information about the quality of drinking water in your area. If you have concerns about the health risks related to the test results of your sample, please contact the Environmental Health Section through the address and telephone number listed below.**

**Branch-Hillsdale-St. Joseph Health Dept**  
**1110 Hill St.**  
**Three Rivers, MI 49093**  
**269 273-2161**

RL: Reporting Limit  
MCL: Maximum Contaminant Level  
AL: Action Level  
Not Detected: Not detected at or above the reporting limit (RL)

mg/L: milligrams / Liter (ppm)  
ng/L: nanograms / Liter (ppt)  
MPN: Most Probable Number

CFU: Colony Forming Unit  
CAS: Chemical Abstract Service  
Laboratory Contact: Marlene Kane

### Official Laboratory Report

Report To: HOLLY GOHLKE  
EGLE-DWEHD-CWSS-LCU  
PO BOX 30817  
LANSING MI 48909-8311

**Sample ID: LL62410**  
**Work Order: 50400091\_11**

System Name/Owner:	01640-BARROWS SCHOOL	WSSN/Pool ID:	
Collection Address:	416 WASHINGTON ST, THREE RIVERS	Source:	Other
Collected By:	ANDY WERT	Site Code:	WIIN
Township/Well#/Section:	//	Collector:	Other
County:	St Joseph	Date Collected:	03/28/2025 10:59
Sample Point:	BAR-1HALL-WC	Date Received:	04/01/2025 13:58
Water System:	Other	Purpose:	Other

TESTING INFORMATION					REGULATORY INFORMATION		
Analyte Name	Result	Units	RL	Date Tested	MCL/AL	Method	CAS #
Lead	0.001	mg/L	0.001	04/03/2025	0.012	EPA 200.8	7439-92-1

The analyses performed by the EGLE Drinking Water Laboratory were conducted using methods approved by the U.S. Environmental Protection Agency in accordance with the Safe Drinking Water Act, 40 CFR parts 141-143, and other regulatory agencies as appropriate.

**Your local health department has detailed information about the quality of drinking water in your area. If you have concerns about the health risks related to the test results of your sample, please contact the Environmental Health Section through the address and telephone number listed below.**

**Branch-Hillsdale-St. Joseph Health Dept**  
**1110 Hill St.**  
**Three Rivers, MI 49093**  
**269 273-2161**

RL: Reporting Limit  
MCL: Maximum Contaminant Level  
AL: Action Level  
Not Detected: Not detected at or above the reporting limit (RL)

mg/L: milligrams / Liter (ppm)  
ng/L: nanograms / Liter (ppt)  
MPN: Most Probable Number

CFU: Colony Forming Unit  
CAS: Chemical Abstract Service  
Laboratory Contact: Marlene Kane

### Official Laboratory Report

Report To: HOLLY GOHLKE  
EGLE-DWEHD-CWSS-LCU  
PO BOX 30817  
LANSING MI 48909-8311

**Sample ID: LL62411**  
**Work Order: 50400091\_12**

System Name/Owner:	01640-BARROWS SCHOOL	WSSN/Pool ID:	
Collection Address:	416 WASHINGTON ST, THREE RIVERS	Source:	Other
Collected By:	ANDY WERT	Site Code:	WIIN
Township/Well#/Section:	//	Collector:	Other
County:	St Joseph	Date Collected:	03/28/2025 10:59
Sample Point:	BAR-1HALL-WC-F	Date Received:	04/01/2025 13:58
Water System:	Other	Purpose:	Other

TESTING INFORMATION					REGULATORY INFORMATION		
Analyte Name	Result	Units	RL	Date Tested	MCL/AL	Method	CAS #
Lead	0.004	mg/L	0.001	04/03/2025	0.012	EPA 200.8	7439-92-1

The analyses performed by the EGLE Drinking Water Laboratory were conducted using methods approved by the U.S. Environmental Protection Agency in accordance with the Safe Drinking Water Act, 40 CFR parts 141-143, and other regulatory agencies as appropriate.

**Your local health department has detailed information about the quality of drinking water in your area. If you have concerns about the health risks related to the test results of your sample, please contact the Environmental Health Section through the address and telephone number listed below.**

**Branch-Hillsdale-St. Joseph Health Dept**  
**1110 Hill St.**  
**Three Rivers, MI 49093**  
**269 273-2161**

RL: Reporting Limit  
MCL: Maximum Contaminant Level  
AL: Action Level  
Not Detected: Not detected at or above the reporting limit (RL)

mg/L: milligrams / Liter (ppm)  
ng/L: nanograms / Liter (ppt)  
MPN: Most Probable Number

CFU: Colony Forming Unit  
CAS: Chemical Abstract Service  
Laboratory Contact: Marlene Kane

## Official Laboratory Report

Report To: HOLLY GOHLKE  
EGLE-DWEHD-CWSS-LCU  
PO BOX 30817  
LANSING MI 48909-8311

**Sample ID: LL62412**  
**Work Order: 50400091\_13**

System Name/Owner:	01640-BARROWS SCHOOL	WSSN/Pool ID:	
Collection Address:	416 WASHINGTON ST, THREE RIVERS	Source:	Other
Collected By:	ANDY WERT	Site Code:	WIIN
Township/Well#/Section:	//	Collector:	Other
County:	St Joseph	Date Collected:	03/28/2025 11:03
Sample Point:	BAR-2HALL-WC	Date Received:	04/01/2025 13:58
Water System:	Other	Purpose:	Other

TESTING INFORMATION					REGULATORY INFORMATION		
Analyte Name	Result	Units	RL	Date Tested	MCL/AL	Method	CAS #
Lead	0.008	mg/L	0.001	04/03/2025	0.012	EPA 200.8	7439-92-1

The analyses performed by the EGLE Drinking Water Laboratory were conducted using methods approved by the U.S. Environmental Protection Agency in accordance with the Safe Drinking Water Act, 40 CFR parts 141-143, and other regulatory agencies as appropriate.

**Your local health department has detailed information about the quality of drinking water in your area. If you have concerns about the health risks related to the test results of your sample, please contact the Environmental Health Section through the address and telephone number listed below.**

**Branch-Hillsdale-St. Joseph Health Dept**  
**1110 Hill St.**  
**Three Rivers, MI 49093**  
**269 273-2161**

RL: Reporting Limit  
MCL: Maximum Contaminant Level  
AL: Action Level  
Not Detected: Not detected at or above the reporting limit (RL)

mg/L: milligrams / Liter (ppm)  
ng/L: nanograms / Liter (ppt)  
MPN: Most Probable Number

CFU: Colony Forming Unit  
CAS: Chemical Abstract Service  
Laboratory Contact: Marlene Kane

## Official Laboratory Report

Report To: HOLLY GOHLKE  
EGLE-DWEHD-CWSS-LCU  
PO BOX 30817  
LANSING MI 48909-8311

**Sample ID: LL62413**  
**Work Order: 50400091\_14**

System Name/Owner:	01640-BARROWS SCHOOL	WSSN/Pool ID:	
Collection Address:	416 WASHINGTON ST, THREE RIVERS	Source:	Other
Collected By:	ANDY WERT	Site Code:	WIIN
Township/Well#/Section:	//	Collector:	Other
County:	St Joseph	Date Collected:	03/28/2025 11:03
Sample Point:	BAR-2HALL-WC-F	Date Received:	04/01/2025 13:58
Water System:	Other	Purpose:	Other

TESTING INFORMATION					REGULATORY INFORMATION		
Analyte Name	Result	Units	RL	Date Tested	MCL/AL	Method	CAS #
Lead	0.008	mg/L	0.001	04/03/2025	0.012	EPA 200.8	7439-92-1

The analyses performed by the EGLE Drinking Water Laboratory were conducted using methods approved by the U.S. Environmental Protection Agency in accordance with the Safe Drinking Water Act, 40 CFR parts 141-143, and other regulatory agencies as appropriate.

**Your local health department has detailed information about the quality of drinking water in your area. If you have concerns about the health risks related to the test results of your sample, please contact the Environmental Health Section through the address and telephone number listed below.**

**Branch-Hillsdale-St. Joseph Health Dept**  
**1110 Hill St.**  
**Three Rivers, MI 49093**  
**269 273-2161**

RL: Reporting Limit  
MCL: Maximum Contaminant Level  
AL: Action Level  
Not Detected: Not detected at or above the reporting limit (RL)

mg/L: milligrams / Liter (ppm)  
ng/L: nanograms / Liter (ppt)  
MPN: Most Probable Number

CFU: Colony Forming Unit  
CAS: Chemical Abstract Service  
Laboratory Contact: Marlene Kane

### Official Laboratory Report

Report To: HOLLY GOHLKE  
EGLE-DWEHD-CWSS-LCU  
PO BOX 30817  
LANSING MI 48909-8311

**Sample ID: LL62414**  
**Work Order: 50400091\_15**

System Name/Owner:	01640-BARROWS SCHOOL	WSSN/Pool ID:	
Collection Address:	416 WASHINGTON ST, THREE RIVERS	Source:	Other
Collected By:	ANDY WERT	Site Code:	WIIN
Township/Well#/Section:	//	Collector:	Other
County:	St Joseph	Date Collected:	03/28/2025 11:04
Sample Point:	BAR-201-CF	Date Received:	04/01/2025 13:58
Water System:	Other	Purpose:	Other

TESTING INFORMATION					REGULATORY INFORMATION		
Analyte Name	Result	Units	RL	Date Tested	MCL/AL	Method	CAS #
Lead	0.054	mg/L	0.001	04/04/2025	0.012	EPA 200.8	7439-92-1

The analyses performed by the EGLE Drinking Water Laboratory were conducted using methods approved by the U.S. Environmental Protection Agency in accordance with the Safe Drinking Water Act, 40 CFR parts 141-143, and other regulatory agencies as appropriate.

**Your local health department has detailed information about the quality of drinking water in your area. If you have concerns about the health risks related to the test results of your sample, please contact the Environmental Health Section through the address and telephone number listed below.**

**Branch-Hillsdale-St. Joseph Health Dept**  
**1110 Hill St.**  
**Three Rivers, MI 49093**  
**269 273-2161**

RL: Reporting Limit  
MCL: Maximum Contaminant Level  
AL: Action Level  
Not Detected: Not detected at or above the reporting limit (RL)

mg/L: milligrams / Liter (ppm)  
ng/L: nanograms / Liter (ppt)  
MPN: Most Probable Number

CFU: Colony Forming Unit  
CAS: Chemical Abstract Service  
Laboratory Contact: Marlene Kane



### Official Laboratory Report

Report To: HOLLY GOHLKE  
EGLE-DWEHD-CWSS-LCU  
PO BOX 30817  
LANSING MI 48909-8311

**Sample ID: LL62415**  
**Work Order: 50400091\_16**

System Name/Owner:	01640-BARROWS SCHOOL	WSSN/Pool ID:	
Collection Address:	416 WASHINGTON ST, THREE RIVERS	Source:	Other
Collected By:	ANDY WERT	Site Code:	WIIN
Township/Well#/Section:	//	Collector:	Other
County:	St Joseph	Date Collected:	03/28/2025 11:04
Sample Point:	BAR-201-CF-F	Date Received:	04/01/2025 13:58
Water System:	Other	Purpose:	Other

TESTING INFORMATION					REGULATORY INFORMATION		
Analyte Name	Result	Units	RL	Date Tested	MCL/AL	Method	CAS #
Lead	0.017	mg/L	0.001	04/03/2025	0.012	EPA 200.8	7439-92-1

The analyses performed by the EGLE Drinking Water Laboratory were conducted using methods approved by the U.S. Environmental Protection Agency in accordance with the Safe Drinking Water Act, 40 CFR parts 141-143, and other regulatory agencies as appropriate.

**Your local health department has detailed information about the quality of drinking water in your area. If you have concerns about the health risks related to the test results of your sample, please contact the Environmental Health Section through the address and telephone number listed below.**

**Branch-Hillsdale-St. Joseph Health Dept**  
**1110 Hill St.**  
**Three Rivers, MI 49093**  
**269 273-2161**

RL: Reporting Limit  
MCL: Maximum Contaminant Level  
AL: Action Level  
Not Detected: Not detected at or above the reporting limit (RL)

mg/L: milligrams / Liter (ppm)  
ng/L: nanograms / Liter (ppt)  
MPN: Most Probable Number

CFU: Colony Forming Unit  
CAS: Chemical Abstract Service  
Laboratory Contact: Marlene Kane